

Low-Emitting Materials

Certificate of Compliance

Awarded to: **TANDUS-CENTIVA, INC. OF DALTON, GA**

Category: Adhesives, Primers and Seam Sealers
Cert. Scheme: VOC Content

Compliance Designation: LEED 2009 and v4 ID&C and BD&C
South Coast Air Quality Management District Rule 1168
VOC content adhesives and sealants

Compliant Products:	RS Adhesive 354	15.6 grams/liter	RS Adhesive 319	<0.5 grams/liter
	RS Adhesive 200	<0.5 grams/liter	B-19 Adhesive	<0.5 grams/liter
	C-12 Adhesive	<0.5 grams/liter	C-14 Adhesive	31.2 grams/liter
	C36 Adhesive	<0.5 grams/liter	C56 Primer	<0.5 grams/liter
	C350 Adhesive	45.5 grams/liter	CEX Adhesive	<0.5 grams/liter
	CTR Adhesive	<0.5 grams/liter	CXL Seam Sealer	<0.5 grams/liter

Test Date: May 20, 2016
& Report No.: 1600661

Certificate No.: MAS1600661

valid May 2016 thru May 2017



Technical Director



Emissions Group Manager



Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025: 2015 certificate # 2925.01
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065: 2016 certificate # 2925.02